

## FULLERTON FIRE DEPARTMENT

# FIRE PREVENTION STANDARDS

### APPLICATION:

PREMISES IDENTIFICATION

### JUSTIFICATION:

2016 CALIFORNIA FIRE CODE (CFC), CHAPTER 5, SECTION 505

### STANDARDS:

#### I. General:

Approved address numbers shall be placed on all new and existing buildings in such a position as to be plainly visible and legible from the street or road fronting the property and alley serving said property. Numbers shall plainly visible from the corresponding street. If the number does not face the street to which it belongs, the number and the street name shall be placed on the building. Address numbers shall be placed in such a manner as to be visible for approaching fire apparatus from both directions (do not place address numbers or letters inside recessed portions of the building). Numbers shall contrast with their background.

Front address numbers for residential shall be a minimum of **4 inches**. Front address numbers for commercial shall be a minimum of **6 inches**. **Add to the minimum size 1 inch for every 10 feet from the public street with a 14 inch maximum**. Use **2 to 3 inch** numbers for the rear address, and mount numbers or letters above the door(s).

#### *Example:*

100 - When facing the corresponding street.  
100 N. Raymond - Not facing the corresponding street.

#### II. Street or Road Signs:

When required by the Chief, streets and roads shall be identified with approved signs.