

### First Quarter Test Results - April/May 2019

Source	PFOA (ng/L)	PFOS (ng/L)	PFOA+PFOS (ng/L)
Well 3A	16.25	47.35	63.95
Well 5	8.4	19.6	28.05
Well 6	6.15	14.95	21.1
Well 8	7.1	17.45	24.55
Main Plant Forebay	8.6	20.1	28.7

### Second Quarter Test Results - August 2019

Source	PFOA (ng/L)	PFOS (ng/L)	PFOA+PFOS (ng/L)
Well 3A	16.9	48	64.9
Well 5	9.8	23.7	33.6
Well 6	6.6	15.5	22.1
Well 8	8.7	16.9	25.6
Main Plant Forebay	9.5	22.1	31.6

### Third Quarter Test Results - October 2019

Source	PFOA (ng/L)	PFOS (ng/L)	PFOA+PFOS (ng/L)
Well 3A	19.2	46.3	65.5
Well 5	14.6	31.8	46.4
Well 6	7.6	16.4	24
Well 8	9.5	18.9	28.4
Main Plant Forebay	9	18.1	27.7

### Fourth Quarter Test Results - January 2020

Source	PFOA (ng/L)	PFOS (ng/L)	PFOA+PFOS (ng/L)
Well 3A	14.9	38.4	53.3
Well 5	11.5	23.7	35.2
Well 6	6.3	12.8	19.1
Well 8	7.3	14.7	22
Main Plant Forebay	7.8	14.8	22.6

ng/L = nanograms per liter (parts per trillion)